

Certificate of Product Approval

Certificate Number: 295a

Issue: 01

Rolland Sprinklers

235 Route de la Biolle
ZA le Sauvage
Mognard
73410
France



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Sprinkler heads

(refer to attached appendix for details)

Standards

EN 12259-1:1999 + Amendment A3:2006

Fixed firefighting systems. Components for sprinkler and water spray systems. Sprinklers

This certificate and appendix is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

RE Brown

Signed for BRE Global Ltd.

Robert Brown

Verifier

19 March 2018

Date of Issue

19 March 2018

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

Appendix to Certificate No: 295a Rolland Sprinklers

Issue: 01

Sprinkler heads

Product Name	Nominal Orifice Size (mm)	Type	Temperature Rating (°C)	LPCB Ref. No.
† Rolland Model N (1),(2)	15	SP	57, 68, 79, 93, 141 (quick response)	295a/01
† Rolland Model N (1),(2)	15	SU	57, 68, 79, 93, 141 (quick response)	295a/01
† Rolland Model N (1),(2)	15	CU/P	57, 68, 79, 93, 141 (quick response)	295a/01
† Rolland Model N (1),(2)	15	SP	57, 68, 79, 93, 141, 182 (5mm bulb)	295a/02
† Rolland Model N (1),(2)	15	SU	57, 68, 79, 93, 141, 182 (5mm bulb)	295a/02
† Rolland Model N (1),(2)	15	CU/P	57, 68, 79, 93, 141, 182 (5mm bulb)	295a/02

Notes:

- (1) Also approved with chromium and painted finishes.
- (2) Also approved for use without temperature sensing element for open head applications.

This certificate and appendix is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

RE Brown

Signed for BRE Global Ltd.

Robert Brown

Verifier

19 March 2018

Date of Issue

19 March 2018

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.

